

**Mandatory Language for Monitoring and Reporting Violation  
Chemical Sampling  
CHEMICAL MONITORING, ROUTINE (DBP), MAJOR/CHLORINE**

The **LATIGO RANCH SUBDIVISION** water system **PWS ID 0100096** has violated the monitoring/reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems are required to properly disinfect water before distribution, maintain acceptable disinfection residuals within the distribution system, monitor the disinfectant residual at various locations throughout the distribution system collect and report the results of that monitoring to the TCEQ on a quarterly basis.

We failed to monitor and/or report the following constituents: **CHLORINE**

This/These violation(s) occurred in the monitoring period(s) - **10/01/2023 - 12/31/2023**

Results of regular monitoring are an indicator of whether or not your drinking water is safe from microbial contamination.

We are taking the following actions to address this issue:

**Chlorine analysis was conducted and recorded daily to ensure water quality, but the Texas Water Company did not submit the quarterly report to TCEQ in a timely manner. We are enhancing the training to our operators and ensuring better communication as to the responsibility of these reports and distinguish best practice for delivery.**

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Ronnie Rodriguez at (830) 730-7240.

Posted /Delivered on: **6JUNE24**